

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHC/KKN/S/2026-27Dated 27-4-2026

It is certified that an inspection team headed by DR. ANIL KUMAR S  
 (Name of Officers with designation) from PHC KOKKARNE  
 (Name of Department/ Office) inspected the VSS English medium  
Lower Primary School (Name & Address of the school) on 22-4-2026

(Date of inspection) checked the water test report Submitted by school and found that the school has portable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year

Signature with Seal: .....

Name : DR. ANIL KUMAR SDesignation : MEDICAL OFFICER  
PRIMARY HEALTH CENTRE  
KOKKARNE - 576 234  
UDUPI TQ. & DISTRICT

Assistant Engineer

of the Govt. Public Health Department (PHED)/

Authorised officer of the local body

Name &amp; Address of the Office / Department

To The PrincipalVSS English medium Lower Primary SchoolMuddur, Nalkur post & VillageBrahmanur Tq. Udupi Dist. 576234.

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK  
Udupi District Water Testing Laboratory, 1<sup>ST</sup> Floor, Old Zillapanchayath Building, Bannanje ,Udupi-576101

TEST REPORT

Address : VSS English Medium Lower Primary School,  
Muddur, Nalkoor Post & Village,  
Brahmavar Taluk,Udupi district  
Karnataka

Report date: 04.04.2026  
Reference: Test Request form  
Sample receipt date: 01.04.2026  
Sample code: NA  
Date of Sample collection: 01.04.2026  
Analysis start date: 02.04.2026  
Analysis completion date: 02.04.2026  
Sample collection protocol: NA  
Sample quantity: 1 liter

Sample Particulars: Open well

Sl.No	Test	Results	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012	Protocol
Description: Colourless liquid					
1.	pH Value @25°C	7.09	6.5 – 8.5	No relaxation	IS 3025 (Part-11) :2022
2.	Specific Conductance, $\mu$ S/cm@25°C	366.8	NA	NA	IS 3025 (Part-14) :2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	0.8	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids , mg/l	141	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO <sub>3</sub> , mg/l	134.64	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO <sub>3</sub> , mg/l	44.04	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	8.01	75	200	IS 3025 (Part-40) : 2024
10.	Magnesium as Mg, mg/l	5.83	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	22.83	250	1000	IS 3025 (Part-32) : 2025
12.	Sulphate as SO <sub>4</sub> , mg/l	2.09	200	400	IS 3025 (Part-24/sec1) : 2022
13.	Fluoride as F, mg/l	0.51	1	1.5	APHA 24 <sup>th</sup> Edition
14.	Nitrate as NO <sub>3</sub> , mg/l	0.96	45	No relaxation	APHA 24 <sup>th</sup> Edition
15.	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2024

Remarks: The above tested parameters are within the acceptable limit as per IS 10500:2012 drinking water specification.

(Nagaveni K.V, Technical Manager)  
Authorized Signatory

RDWSD/WQMSP/TeR/01

Note:

1. The above results relate only to the sample tested.
2. The report shall not be reproduced except in full without the prior approval of the Quality Manager.
3. Traceability: Traceability of measurements is established using CRM traceable to National/International standards.
4. Samples will be discarded after 15 days from the date of report generation.
5. Decision rules applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

-----END OF REPORT-----